

CERTIFICADO DE CALIBRACIÓN / CALIBRATION CERTIFICATE

INNOVATECIS CIA LTDA

General José María Guerrero N69-170 y Alfonso del Hierro

Quito, Ecuador

(+593) 02 6040 607

innovatec@innovatec.com.ec

Certificado No. (Certificate #): 61036

Fecha de Recepción (Reception Date): 2025-09-08

Fecha de Calibración (Calibration Date): 2025-09-10

Próxima Fecha de Calibración (Calibration Due): 2026-09

Fecha de Emisión (Emission Date): 2025-09-10

Cliente (Client): GAD Municipal Tena
CRTV Tena, Barrio 3 de Mayo, Tena

Información del Instrumento (Instrument Information)

Equipo (Instrument):	Sonómetro	Int. de Medición: (Measurement Range)	(30 a 140) dB	Ubicación: (Location)	*****
Marca (Brand):	Cesva				
Modelo (Model):	SC101	División de escala: (Resolution)	0.1 dB	Lugar de Calibración: (Place of Calibration):	Lab. INNOVATEC INNOVATEC's Lab.
Serie (Serial #):	T253616				
Código (Code):	*****				

Datos de Calibración (Calibration Info)

Procedimiento (Procedure): INN-PC-15

Condiciones Ambientales (Environmental Conditions)

Temperatura (Temp): (21.1 °C a 21.4 °C)

Humedad (Humidity): (56.4 %HR a 55.9 %HR)

Trazabilidad (Traceability Info)

Patrón (Standard)	Marca (Brand)	Cert. #	Última Calibración (Last Cal.)	Período (Period)
Multímetro Patrón	Transmille	AC-28786	2023-06-08	2.5 años
Medidor Acústico	Reed	US011-MIL-CI-23222062	2023-09-18	2 años
Calibrador Acústico	Reed	US011-MIL-CI-23222187	2023-09-18	2 años

Resultados (Results)

Ver Resultados en Hoja Adjunta

See results in attached Sheet

El presente Certificado de Calibración posee la trazabilidad en esta magnitud hacia el Patrón Nacional, a través de la realización de la unidad de medida en el NPL, NIST, o otro Laboratorio Nacional reconocido al Sistema Internacional de Medidas. La calibración fue realizada bajo un Sistema de Gestión de Laboratorio conforme a la Norma ISO/IEC 17025:2017. Los resultados y su incertidumbre reportada con un nivel de confianza de K=2, 95% son relacionados a este instrumento y en el tiempo que se realizó las medidas. Este Laboratorio no se responsabiliza de los perjuicios que pueda ocasionar el uso inadecuado del instrumento calibrado. La reproducción parcial es prohibida, la reproducción total deberá hacerse con la autorización escrita aprobada por INNOVATEC Industrial Solutions. *This Certificate of Calibration provides traceability of measurement to the National Standard, through units of measurement realized at the NPL, NIST or other recognized National Standard Laboratories to the International System of Units. The calibration was performed under a Laboratory Management System in accordance with the ISO/IEC 17025:2017 Standard. The results and the reported uncertainty at a confidence level of K=2, 95% are related only to this instrument and at the time of measurement. This Laboratory is not responsible for any damages that may result from improper use of the calibrated instrument. Partial reproduction is forbidden, the total reproduction must have an approved written authorization by INNOVATEC Industrial Solutions.*

Comentarios: Los valores marcados con "#", no se encuentran dentro del Alcance de Acreditación de A2LA, pero si en la competencia técnica de INNOVATEC Industrial Solutions.
Comments

Calibrado por:
Calibrated by: Jonathan Fonseca

Aprobado por:
Approved by:

Fin de Certificado (End of Certificate)

Certificado No.:

61036

Equipo (Instrument):

Sonómetro

Fecha de Calibración:

2025-09-10

Marca (Brand):

Cesva

Tipo (Type)	Rango (Range)	Patrón (Standard)	UBP (UUT)	Error (Error)	Incertidumbre (Uncertainty)
Eléctrica	(20 a 140)dB @250 Hz	1.794 V (69.7 dB)	69.8 dB	0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @250 Hz	2.274 V (93.7 dB)	93.7 dB	0.0 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @250 Hz	2.674 V (113.7 dB)	113.8 dB	0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @500 Hz	1.796 V (69.8 dB)	69.7 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @500 Hz	2.276 V (93.8 dB)	93.7 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @500 Hz	2.676 V (113.8 dB)	113.6 dB	-0.2 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @1 kHz	1.804 V (70.2 dB)	70.1 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @1 kHz	2.286 V (94.3 dB)	94.2 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @1 kHz	2.686 V (114.3 dB)	114.2 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @2 kHz	1.796 V (69.8 dB)	70 dB	0.2 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @2 kHz	2.276 V (93.8 dB)	93.9 dB	0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @2 kHz	2.676 V (113.8 dB)	113.7 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @4 kHz	1.794 V (69.7 dB)	69.7 dB	0.0 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @4 kHz	2.274 V (93.7 dB)	93.8 dB	0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @4 kHz	2.686 V (114.3 dB)	114.2 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @8 kHz	1.804 V (70.2 dB)	70.1 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @8 kHz	2.286 V (94.3 dB)	94.3 dB	0.0 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @8 kHz	2.686 V (114.3 dB)	114.2 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @12.5 kHz	1.794 V (69.7 dB)	69.5 dB	-0.2 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @12.5 kHz	2.274 V (93.7 dB)	93.8 dB	0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @12.5 kHz	2.686 V (114.3 dB)	114.2 dB	-0.1 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @16 kHz	1.804 V (70.2 dB)	70 dB	-0.2 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @16 kHz	2.286 V (94.3 dB)	94.5 dB	0.2 dB	± 0.058 mV
Eléctrica	(20 a 140)dB @16 kHz	2.686 V (114.3 dB)	114.2 dB	-0.1 dB	± 0.058 mV
Acústica Ponderación A#	(20 a 140)dB @1 kHz	70 dB	70 dB	0.0 dB	± 0.40 dB
Acústica Ponderación A	(20 a 140)dB @1 kHz	94 dB	94 dB	0.0 dB	± 0.40 dB
Acústica Ponderación A	(20 a 140)dB @1 kHz	114 dB	114 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C#	(20 a 140)dB @1 kHz	70 dB	69.9 dB	-0.1 dB	± 0.40 dB
Acústica Ponderación C	(20 a 140)dB @1 kHz	94 dB	94 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C	(20 a 140)dB @1 kHz	114 dB	114 dB	0.0 dB	± 0.40 dB
Acústica Ponderación A#	(20 a 140)dB @2 kHz	70 dB	69.9 dB	-0.1 dB	± 0.40 dB
Acústica Ponderación A	(20 a 140)dB @2 kHz	94 dB	94 dB	0.0 dB	± 0.40 dB
Acústica Ponderación A	(20 a 140)dB @2 kHz	114 dB	114 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C#	(20 a 140)dB @2 kHz	70 dB	70.1 dB	0.1 dB	± 0.40 dB
Acústica Ponderación C	(20 a 140)dB @2 kHz	94 dB	94 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C	(20 a 140)dB @2 kHz	114 dB	114 dB	0.0 dB	± 0.40 dB
Acústica Ponderación A#	(20 a 140)dB @8 kHz	70 dB	70.1 dB	0.1 dB	± 0.40 dB
Acústica Ponderación A	(20 a 140)dB @8 kHz	94 dB	94 dB	0.0 dB	± 0.40 dB
Acústica Ponderación A	(20 a 140)dB @8 kHz	114 dB	114 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C#	(20 a 140)dB @8 kHz	70 dB	70 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C	(20 a 140)dB @8 kHz	94 dB	94 dB	0.0 dB	± 0.40 dB
Acústica Ponderación C	(20 a 140)dB @8 kHz	114 dB	114 dB	0.0 dB	± 0.40 dB

IS 15575 (Part 1) : 200
IEC 61672 -1 (2002)

C.2.2 The onset time constant of the special signal detector is small compared with the 35 ms time constant. The design-goal decay rate of the detector is 2,9 dB/s with tolerance limits of $\pm 0,8$ dB/s and $\pm 1,3$ dB/s for class 1 and class 2 sound level meters, respectively. The design-goal decay rate and the tolerance limits for design and manufacture correspond approximately to a decay time constant of $1\,500\text{ ms} \pm 250\text{ ms}$ and $1\,500\text{ ms} \pm 500\text{ ms}$ for class 1 and class 2 sound level meters, respectively.

C.2.3 Sound level meters with time-weighting I should respond to single sinusoidal tonebursts and to sequences of sinusoidal tonebursts in accordance with the tests given in C.3.

C.2.4 For steady sinusoidal electrical input signals with frequencies from 315 Hz to 8 kHz sound levels measured with time-weightings F and I should be the same within 0,4 dB. For a single short toneburst, the sound level displayed with time-weighting I generally is greater than the sound level displayed with time-weightings F or S.

C.3 Tests of I-time-weighted sound level

C.3.1 For single 4 kHz sinusoidal electrical tonebursts of specified durations, table C.1 gives the corresponding design goals for the highest A-frequency-weighted, I-time-weighted sound level relative to the A-weighted sound level displayed for the steady signal. Measurement deviations from the design goals, extended by the actual expanded uncertainties of measurement, should be within the applicable tolerance limits. Tonebursts should be extracted from the steady 4 kHz input signal that produces a display of the A-frequency-weighted sound level stated in the instruction manual for the upper limit of the reference level range.

Table C.1 – Design goals for the relative response of A-frequency-weighted, I-time-weighted sound level to single 4 kHz tonebursts, with tolerance limits

Toneburst duration T_b ms	Highest response to a toneburst minus the response to a steady signal ^{a)} dB	Tolerance limits, dB	
		Class	
		1	2
20	-3,6	$\pm 1,8$	$\pm 2,3$
5	-8,8	$\pm 2,3$	$\pm 3,3$
2	-12,6	$\pm 2,3$	...

^{a)} Calculated from $10 \lg(1 - e^{-T_b/\tau})$,
where
 T_b is the specified toneburst duration in seconds; and
 τ is the 0,035 s time constant for time-weighting I.

C.3.2 For class 1 sound level meters, when the level of a 2 ms, 4 kHz toneburst is changed by 10 dB, the display of the A-frequency-weighted, I-time-weighted sound level should change by $10\text{ dB} \pm 1,3\text{ dB}$. For class 2 sound level meters, when the level of a 5 ms, 4 kHz toneburst is changed by 5 dB, the display of the A-frequency-weighted, I-time-weighted sound level should change by $5\text{ dB} \pm 1,3\text{ dB}$.

15

re
ce
re
id
or

al
in

z,
a
er

is
id
id
of
re
re
re

[
[
[
[
[
[
[
[

id
je
st
el

IS 15575 (Part 1) : 2005
IEC 61672 -1 (2002)

Table 1 – Directional response limits including maximum expanded uncertainty of measurement

Frequency kHz	Maximum absolute difference in displayed sound levels at any two sound-incidence angles within $\pm\theta$ degrees from the reference direction dB					
	$\theta = 30^\circ$		$\theta = 90^\circ$		$\theta = 150^\circ$	
	Class					
	1	2	1	2	1	2
0,25 to 1	1,3	2,3	1,8	3,3	2,3	5,3
>1 to 2	1,5	2,5	2,5	4,5	4,5	7,5
>2 to 4	2,0	4,5	4,5	7,5	6,5	12,5
>4 to 8	3,5	7,0	8,0	13,0	11,0	17,0
>8 to 12,5	5,5	...	11,5	...	15,5	...

NOTE Maximum absolute differences in displayed sound levels are extended by the expanded uncertainty of measurement for demonstration of conformance to the limits given above.

5.3.2 For any frequency within the specified ranges, the requirements of table 1 apply for any orientation of the sound level meter, or applicable components, around the reference direction.

5.4 Frequency weightings

5.4.1 At 1 kHz, the design goal for all frequency weightings is 0 dB with corresponding tolerance limits of $\pm 1,1$ dB for class 1 sound level meters and $\pm 1,4$ dB for class 2 sound level meters.

5.4.2 Table 2 gives the frequency weightings A, C, and Z, rounded to a tenth of a decibel and corresponding tolerance limits for class 1 and class 2 sound level meters. For a given performance class, tolerance limits in table 2 apply on all level ranges and after applying the adjustment described in 5.2 for the response to the sound calibrator at the calibration check frequency and under reference environmental conditions.

IS 15575 (Part 1) : 2005
IEC 61672 -1 (2002)

5.18.3 For group Y and group Z sound level meters, the maximum disturbance conducted to the public supply of electric power shall be within the quasi-peak and average voltage-level limits given in table 5 at an a.c. power port. If the sound level meter conforms to the limit for the average voltage of conducted disturbances when using a quasi-peak measuring device, the sound level meter shall be deemed to conform to the quasi-peak and average voltage limits.

Table 5 – Limits for conducted disturbance to the voltage of a public supply of electric power including maximum expanded uncertainty of measurement

Frequency range MHz	Limits on voltage level of disturbance (re 1µV) dB	
	Quasi-peak	Average
0,15 to 0,50	66 to 56	56 to 46
0,50 to 5	56	46
5 to 30	60	50

NOTE 1 See 4.1.2 of CISPR 16-1:1999 for the characteristics of quasi-peak-measuring receivers.

NOTE 2 Lower limits for voltage levels apply at the transition frequencies.

NOTE 3 Voltage level limits decrease linearly with the logarithm of the frequency in the range from 0,15 MHz to 0,50 MHz.

5.19 Crosstalk

5.19.1 Crosstalk, or leakage of signals between pairs of channels, is a concern for multi-channel sound level meters.

5.19.2 At any frequency within the range of a class 1 or class 2 multi-channel sound level meter system, the difference between the level indicated on the display device, in response to a steady electrical signal applied to the electrical input facility of one channel and adjusted to indicate the upper limit of the applicable linear operating range, and the signal level indicated for any other channel shall be at least 70 dB. Termination devices, as stated in the instruction manual, shall be installed in place of the microphones on the other inputs.

5.20 Power supply

5.20.1 An indication shall be provided to confirm that the power supply is sufficient to operate the sound level meter within the specifications of this standard.

5.20.2 The instruction manual shall state the maximum and minimum power supply voltage at which the sound level meter conforms to the specifications of this standard. With a sound calibrator applied to the microphone, the change in the displayed sound level, extended to include the expanded uncertainty of measurement, shall not exceed $\pm 0,3$ dB for class 1 sound level meters and $\pm 0,4$ dB for class 2 sound level meters when the supply voltage is reduced from the maximum to the minimum.

5.20.3 If internal batteries are used to power the sound level meter, the acceptable battery types shall be stated in the instruction manual and preferably on the instrument. The instruction manual shall also state the continuous operating time, under reference environmental conditions, to be expected for the specified normal mode of operation when capacity batteries are installed.

d to
avel
t on
rice,
age

ric



ulti-

avel
e to
d to
ited
tion

t to

ges
und
l by
avel
rom

tery
The
nce
full

12

24

